ISSN (Online) 2395-2717

International Journal of Engineering Research in Electrical and Electronic Engineering (IJEREEE)

Volume 12, Issue 09, September 2025

Performance Optimization of Concentrated Solar Power Plants through Technological Innovations

[1] Maulik Patel, [2] Dr. Sanjay. R. Vyas

[1] Research Scholar, Engineering & Technology, Kadi Sarva Vishwavidyalaya University, Gandhinagar, Gujarat, India
[2] Department of Electrical Engineering, LDRP ITR, Gandhinagar, Gujarat, India
Corresponding Author Email: [1] mvpatel.eee@gmail.com

Abstract*— This work describes optimization methodologies to maximize the efficiency of CSP plants. CSTs hold great potential for the production of sustainable energy, provided that they are optimized with efficient optimization methods that lead to minimum cost with an acceptable energy capture efficiency. In order to identify the precise areas of a CSP plant where optimisation techniques could be applied to maximise power generation, this study aims to perform a comprehensive examination of the existing literature and industry, boost plant efficiency, and lower production costs overall. The review mainly approaches the essential points including design of solar collectors, thermal energy storage, heat transfer fluids, solar tracking systems, and operational control. The aim is the identification of more efficient and productive energy generating mechanisms. Moreover, the challenges and opportunities related to the application of optimisation techniques to Control Concentrated Solar Power (CSP) plants are presented, as well as potential future research and development directions. This paper will contribute to the efforts of ongoing activities aimed at increasing the performance, sustainability of CSP plants through the incorporation of up-to-date literature, and highlighting potential areas of advancements.

Index Terms- Concentrated Solar Power Systems, Techonological Innovations, Optimization Techniques, Renewable Energy Generation.

I. INTRODUCTION

The production of electricity has been the practice of converting some form of energy into an electric current for decades. For quite some time, fossil fuels have been predominant in energy production. But since they are rare, alternative technologies have been developed. Use of fossil fuels gives rise to increased carbon dioxide (CO2) levels, which has an adverse effect on the climate and promotes natural disasters [1]. It became therefore essential to consider alternative technologies allowing to; on the one hand, to adapt more easily to the new regulations against environmental pollution and, on the other hand, to reduce CO2 emissions. These fall under the category of renewable technologies. This form of energy is unlimited, as suggested by its name. There are the different types of renewable energies which is determined on sources of energy used, for example, water (hydro), Solar Photovoltaic (PV), Wind, among the others [2]. Often referred to as solar thermal energy, concentrated solar power (CSP) is one type of energy that.

A collection of devices created especially to harness solar radiation to generate electricity is known as Concentrated Solar Power (CSP) technology [3]. A popular solar collector, the parabolic trough directs sunlight into a receiver tube that is filled with a heat transfer fluid using mirrors. An array of mirrors is used to focus typical sunlight onto the receiver on top of a tower in solar power tower systems, which are a more common design. In turn, the high temperatures are concentrated in a steam generator, which creates steam that powers a turbine generator to produce electricity [4]. Additionally, dish reflectors are used in dish/stirling systems to direct sunlight onto a receiver, which warms a Stirling engine to produce power. Fresnel reflectors have been described as flat mirrors in striped or honeycom polyester con guration for sunlight concentration in a linear receiver for heat transfer wheresolar chimneys are characterized by a tall chimney surrounded by greenhouse to create anupdra that that rives turbines for energy usage [5]. Each CSP technologies has its own benefits, and applications and resulting in various solar technology [6].

II. LITERATURE REVIEW OF DIFFERENT CSP TECHNOLOGIES

Because it can capture solar radiation and produce electricity on a MW scale, one solar technology that can be utilised as a sustainable energy source is concentrated solar power (CSP). This literature review aims to give a general overview of different Concentrated Solar Power (CSP) technologies, including their principles of operation, advancements, assessments of CSP system efficiency, and economic and environmental considerations. Abbas, R. and Valdes M. This present investigation deals with Facilities in the design and optimization of solar collectors Optimization of a solar collector is the most probable one of the key factors to achieve an efficient performance from the perspective of thermal output. Correction of optical performance and adaptability to different latitudes. 507 compare a new linear Fresnel collector to conventional parabolic trough collectors [7].

A linear Fresnel reflector (LFR) system's hourly and daily performance is examined by E. Bellos and E. Mathioulakis.

ISSN (Online) 2395-2717

International Journal of Engineering Research in Electrical and Electronic Engineering (IJEREEE)

Volume 12, Issue 09, September 2025

With water serving as the working fluid and heated to about 100°C, an LFR system with an inverted flat plate receiver (36 m² collecting aperture area and 1 m³ storage tank) in Athens, Greece, is effective enough to capture solar energy, providing 8.4 kW of useful heat and 260 MJ of heat per day. This research represents valuable lessons for the assessment and the optimization of the integrated solar concentrating systems, especially the linear Fresnel reflector technology. [8]

Saif Al Hamad and Suhil Kiwan The study's main objective is to maximise the CSP system's optical efficacy in the mountainous region by examining geometric features such the tower's height (HT), heliostats field length (Δmin), and mountainous tilt angle. Using Planta Solar 10 (PS10) heliostat field criteria and numerical simulation in MATLAB and PSO to optimise spiral heliostat field distributions, a test case analysis was conducted on a sample CT system based on the Sierra Sun Tower in California, USA. They demonstrate how the distance between the tower and the heliostat field directly affects land use, heliostat numbers, and the optical effectiveness of the system. Not only do spiral distributions of cornfields perform better than parallel ones, but they also require more area, validating the energy generation potential of hillside CSP systems on sloping lands [9].

Bouya M., Ghazouani M. Evaluation and improvement of a fossil fuel energy system with solar assistance for heating a bitumen storage tank while reducing heat loss. Energy and mass balance equations are considered to model the system components, including the small parabolic trough collectors of the system, storage tanks for the cold and warm fluids, and the fossil fuel heater which heats the bitumen. To evaluate the thermo-physical characteristics and heat transfer coefficients for a whole year, hourly recorded sun irradiation, wind speed, and temperature data from Rabat, Morocco are used. Genetic Algorithm and proposed resolution algorithms are applied to maximize rates of replacing fossil fuel and to minimize energy production cost with three double-objective functions. A complete study is presented in this paper detailing the potential improvements in hybrid solar-fossil fuel energy systems aimed for bitumen storage energy efficiency and cost. [10]

In order to validate a mathematical model of dish/stirling system design, modelling, and optimisation, Nazemi S. and Boroushaki M. compare it with experimental data of a system that is similar. Given that calculations reveal significant hot heat losses in the cavity receiver and Stirling engine, the suggested model will be highly helpful for designing and optimising the dish/stirling combination. An optimization method named as Particle Swarm Optimization (PSO) removes losses of pressure drops, conduction, and radiation, which will improve an efficient system. Taking economics into account in manufacturing the solar dish/Stirling system will increase efficiency and feasibility, hence we recommend using the results in practical designs and prototypes and experiment to confirm and refine the system performance [11].

Desai investigated a process utilising a novel configuration for two solar collector fields: a traditional parabolic trough collector (PTC) field with a heat transfer fluid and a linear Fresnel reector (LFR) field that directly generates steam. This part includes with the introductory chapter containing principles of design, brief characteristics of the power plant, information obtained in the process of commissioning and operating the plant, and initial data [12]. At that time the facility is operational, and is aligned to the grid. Preliminary results indicate that performance was bad for the two collector fields survaying the heliostats, misadjustment of the tracking, a circuit loop over-disbalance in the PCT collector field and the inappropriate geometry of the LFR field receiver contributed to the underperformance.

Kumar Abhishek worked on the well-known project named as the Concentrated Solar Power plant. The Plant itself contains all kinds of state-of-the-art and creative technology. In that sense, in the present study we analyze the construction and design of a parabolic reflector of 60 m2, built in situ [13]. The reflector is constructed on a low mass space frame and designed to optimize the solar thermal output. The solar-thermal technology is discussed in this work, where a brief introduction and operations analysis are given. The project is specifically planned to be an off-grid, isolated power plant with the goal of co-generating heat and electricity for Brahmakumaris and the World Renewal Spiritual Trust (Wrst). The existing state of power generation and the potential for solar energy are highlighted.

In this paper optimization practices that are expected to increase efficiency, performance and cost-efficiency of CSP are analyzed. Several types of CSP technology are considered for energy conversion: parabolic trough, central tower, dish/Stirling system and Fresnel reflector. The importance of efficiencies of solar collectors, thermal stores, heat transfer fluids, and solar tracking systems for achieving optimal power yield and maximum operational efficiency is emphasized. It also emphasises the use of software tools such as MATLAB and the System Advisor Model (SAM) to model and evaluate the performance of CSP systems. To assist readers better understand how to generate renewable energy while reducing global pollution, it also includes illustrations. Based on this evaluation, the paper suggests potential optimisations for CSP systems to switch to a more environmentally friendly energy source.

III. OPTIMIZATION METHODOLOGIES FOR CONCENTRATED SOLAR POWER (CSP) PLANTS

Enhancing the effectiveness, dependability, and economic viability of Concentrated Solar Power (CSP) facilities is crucial for enabling humanity to transition to a civilisation reliant on renewable and reversible energy.

A summary of some methods to increase the performance and efficiency of CSP plants is presented.

ISSN (Online) 2395-2717

International Journal of Engineering Research in Electrical and Electronic Engineering (IJEREEE)

Volume 12, Issue 09, September 2025

Optimized Plant Layout and Configuration:

Enhancing the effectiveness and performance of CSP systems requires an ideal architectural and design arrangement [16]. A well-designed design minimizes shading, blocking, and optic loss to improve solar collimation on the receiver as well as to increase the power plants import through a higher efficiency of the plant.

In this regard, the key enabling factors and methods to optimise the layouting of CSP plants are addressed here.

1. Terrain and Topography Considerations
2. Mirror Placement
3. Field Density and Spacing
4. Receiver Location and Orientation
5. Receiver Height and Tilt Angle
6. Integration with Thermal Energy Storage (TES)
7. Optical Performance Analysis

Optimal Site Selection:

How to choose site for the CSP power plant It is very important for CSP power plant project developers or EPC contractors to decide to choose a site for CSP project.

Selection of CSP site numerous elements influence the location choice of CSP, these include: natural conditions (e.g. solar), requirements associated with power generation support services, infrastructure availability (water resources, land use, telecommunications etc.) and social factors.

CSP plants are only allowed during site pre-selection phases if DNI is higher than 1800 (or 5.5) kW h/m2/year (day) [17].

The considerations below are potential things to weigh when selecting an appropriate site.

1. Describe the typical daily radiation levels of the sun, both direct and global.
2. Average annual energy production.
3. Calculate transmission losses under expected conditions.
4. Compare each tested option's Net Transmitted Energy.

Economic Optimization of CSP Electricity:

Strategies for Achieving Optimal Costs:

The levelized cost of electricity, or LCOE, is typically used to analyse the support levels of solar thermal generating plants. Additionally, it heavily depends on the inputs and presumptions. This is the philosophy for determining the LCOE [18].

$$LCOE = \frac{Cref.C_{inv} + C_{O\&M} - C_{env}}{Q_{el,Net}} \quad (1)$$

Where:

C_{inv}: The entire cost of the investment ($).

$C_{o\&m}$: Costs of operations and maintenance per year

C_{env}: Environmental cost according to CO2 rejected

$Ce_{l,Net}$:Net power electric production (kWh).

$$crf = \frac{K_d.(K_d+1)^N}{(K_d+1)^N-1} \quad (2)$$

Where:

k_d : Rate of Annaul discount (%).

N : System depreciation operating time (years).

Optimal Selection of Reflector:

A lot of important factors should be considered in the power comparisons of selecting point focus or line focus collectors of a CSP plant Table 1 lists the solar thermal collectors [15]. The concentration factor is directly related to the operating temperature. Point-focus concentrators produce solar thermal energy of high quality [19]. Applications needing high-grade thermal energy on a wide scale can benefit from the heliostat field collector, while smaller-scale applications can benefit from the parabolic dish collector.

Table 1. Sun thermal collectors that are both concentrating and non-concentrating.

Type of collector	Solar Concentration ratio	Technological maturity	Tracking system	Operating temperature (^{0}C)	Land requirement	Average efficiency solar to electricity (%)
Parabolic trough collector	40-80	High	One-axis	350-450	High	14-16
Linear Fresnel reflector	20-50	Medium	One-axis	200-350	Medium	8-10
Heliostat field collector	500-1200	Medium	Two-axis	500-1000	High	12-18
Parabolic dish collector	800-5000	Low	Two-axis	500-1200	Low	20-30

Optimal Selection of Receiver:

The receiver in a CSP plant is key for a good energy transfer, durability and reliability, heat transfer and economics. In a CSP plan, the receivers are usually connected in series and also doubles as an economizer and super-heater. With this design you achieve the best possible thermal to optical performance when harvesting concentrated solar light. The temperature of the heat transfer fluid increases while flowing sequentially through the receivers. This is akin to the economizer in a conventional thermal power plant

ISSN (Online) 2395-2717

International Journal of Engineering Research in Electrical and Electronic Engineering (IJEREEE)

Volume 12, Issue 09, September 2025

application, where waste/exit heat from the main cycle heats up the inlet water. The series connection also allows further heating of the fluid as a super heating [20]. This raises the temperature of the liquid so that it efficiently runs the turbine and produces electricity. These characteristics optimize the conversion of solar radiation into electrical power in series-strings of receivers and by extension in CSP plant energy yield.

Receiver connecting with series solution could have the following seven improvements for the concentrating solar power (CSP) plant:

1. Optimized energy conversion efficiency.
2. Steady and reliable performance.
3. Optimized Solar Resource Utilization.
4. Enhanced Grid Stability
5. Consistent Energy Output
6. Enhanced system adaptability
7. Enhanced thermal efficiency

Heat Transfer Fluid:

Heat transfer fluid for CSP system types including air, water, molten salts, glycol, glycerol, and synthetic oil are well documented [21]. This fluid is an efficient heat transfer medium. Table 2 lists various heat transfer fluids and their pros and cons. Water is a good heat transfer medium for concentrated solar power even if it is cheap cost, non-toxic, and low viscosity with high heat capacity [28].

Table 2. Advantages and Limitation of Various Heat Transfer Fluid Groups.

Fluidgroup	Advantages	Limitation
Synthetic fluids	➢ Oxidation rates are lower than of mineral oils; ➢ High operating temperatures ➢ Good volumetric heat capabilities (like mineral oils)	• Greater upfront procurement costs compared to mineral oils. • Elevated vapour pressures necessitate more expensive storage containers, especially during elevated temperatures.
Silicone oils	➢ excellent thermal stability ➢ Silicone oils are chemically inert and resistant ➢ Low Flammability	• The priciest fluid group • high viscosities and vapour pressures • Lowvolumetricheatcapacities
Moltensalts	➢ High Thermal Stability ➢ high heat capacity and can store thermal energy efficiently ➢ High Heat Transfer Efficiency ➢ Economic Benefits	• High freezing points may require additional equipment • High viscosities increase pumping costs
Water	➢ Abundant. ➢ High Specific Heat Capacity ➢ Thermal conductivity ➢ Low viscosities ➢ Very low cost ➢ Non-toxic and environmentally friendly	• Restrictions on the design of materials to deal with corrosion. • Vapour pressures over 100°C result in more expenses for storing. • Pressure-related exposure extenuation strategies (or a more limited operating temperature range)

Solar Tracking

Sun following to enhanced productivity and efficiency of concentrated solar power (CSP) plants and supports a long-term sustainable way of natural resources utilisation. Tracking systems on two axis turn, on one horizontal axis they tilt. Dual-axis trackers generate more electric energy per year than single-axis trackers, primarily due to changes in seasonal sun ray angle [22].

Table 3. Axis rotation-based comparison of the Solar Tracking System.

Properties	**Single-Axis**	**Dual-Axis**
Number of Axis	It is limited to only one axis	It is limited to having only two axes
Complexity	Less complex	High complexity
Tracking accuracy	It offers the least accuracy compared to the other types of trackers	It offers high accuracy compared to the single-axis
Cost	Cheap to implement	More expensive to implement Than a single but less expensive than a hybrid

ISSN (Online) 2395-2717

International Journal of Engineering Research in Electrical and Electronic Engineering (IJEREEE)

Volume 12, Issue 09, September 2025

IV. CONCENTRATING SOLAR POWER PLANT



Figure 1: Layout for solar parabolic dish power plant

A parabolic dish type CSP (concentrated solar power) generation facility uses a solar parabolic dish to precisely focus sunlight on a receiver so that intense sunlight is converted into heat. This heat is used to heat a working fluid, then being stored in buffer stream storage for further use. The purpose of Pump 1 is to move this steam to the Low-Pressure (LP) and High-Pressure (HP) turbines, where it generates mechanical energy that powers the generator to produce electricity. After its flow through the turbines the steam is cooled in the condensor, and there collected in the hotwell. In dissipating the excess heat in the condenser, the cooling tower is essential. At the same time, raw water stored in the underground tank is purified in the water treatment plant so as to satisfy demanded quality requirements. Pump 2 serves to feed this treated water to cooling system and Pump 3 to circulate it to in the power plant [14]. Furthermore, dissolved gases are effectively removed from the feedwater by the deaerator to help avoid corrosion and increase system efficiency.

At night or when the weather is overcast, the heated molten salt is pumped back to the cold tank, passing through the heat exchanger. This operation gives the oil circuit the possibility to recover heat energy and produce steam and work cyclically [15].

V. TECHNICAL SPECIFICATIONS FOR THE SIMULATION

Table 4. Key simulation inputs for India One CSP Plant, Rajasthan [19]

Sr. No	Project	Detail
1	Project	India One Solar Thermal Power Plant
2	Location and country	Brahma Kumaris Shantivan Campus, Abu Rajasthan (India)
3	Lat/Long Location	26° 42' 9.36"North 77° 51' 13.64" East
4	Focusing	Point Focus
5	Technology	60 SQM parabolic reflector disc
6	Turbine Capacity	1.2 Mw
7	Steam Pressure	38 to 42 Bar
8	Heat Transfer Fluid Type	Water
9	Cooling Method	Air
10	Solar Field obtain Temperature	450 to 650 ^{0}C
11	Storage Type	Thermal storage
12	Static focus concentration Ratio	350:1
13	Tracking	Two-axis
14	Annual solar to electric efficiency	16-20
15	Peak solar-to-electric efficiency	22–26
16	Power Cycle	Steam Rankine
17	solar electricity generation	1.2 MW
18	Application	Solar power generation, cooking, water heating.

ISSN (Online) 2395-2717

International Journal of Engineering Research in Electrical and Electronic Engineering (IJEREEE)

Volume 12, Issue 09, September 2025

VI. SIMULATION OF RESULTS AND DISCUSSION

The electrical energy generated by the CSP plant considered is strongly related to the solar resource of the selected region and to the thermal storage size. During the analysis, a number of characteristics are monitored and analysed, including the working fluid temperature and the performance involving sun radiation. The power generation versus the total received solar radiation in the proposed CSP power plant is plotted in Fig.6.4. The proposed CSP power plant is situated at latitude 26° 42' 9.36"North & 77° 51' 13.64" East and founded on Brahma Kumaris Shanti van Campus, Abu (Rajasthan) (India).

This includes simulation tools in MATLAB that can model and simulate power generation, enabling the performance and influence of the system to be studied in details. The System Advisor Model (SAM) software is used in studies. It is developed by the National Renewable Energy Laboratory (NREL) with funding from the U.S. Department of Energy.



Figure 2: changes in solar radiation throughout time

Figure 2 shows the change in sun radiation from 8:00 to 18:00 hours. In mid-morning, the radiation level increases and at about 11:00–12:00 hours reaches its maximum level at about 920 W/m² and later decreases in the afternoon lowering near to zero in the evening. This daily cycle replicates the normal sunlight/daylight cycle.



Figure 3: Variation of temperature with time

The variation of the temperature from 8h00 to 18h00 is illustrated in Figure 3. The temperature tends to increase in the morning until it's at around 600 °C in late morning, where it remains almost constant until the early afternoon. It gradually decreases throughout the evening then falls to near zero tallies.

Hourly steam generation is shown in Figure 6.3 from hour 8 to 18 h. The steam yield rises continuously in the morning, with peaks at around 11:00–12:00 h, declining slowly in the evening. Average steam generation per day is 2563 kg of steam.



Fig. 4: Production of Steam (Kg/Hour)

Figure 4 shows the CSP system's net power output during the day. Just before noon, power generation rises sharply in the morning to roughly 1050 kW, and then it progressively falls again in the afternoon. This is consistent with how solar energy varies throughout the day. As previously mentioned in Figure 4, if daily generation exceeds the threshold, it can be managed by either increasing the water flow rate or utilising other safety systems that can function in high-pressure, high-temperature reactor core circumstances.



Figure 4: Typical net power output profile of CSP

ISSN (Online) 2395-2717

International Journal of Engineering Research in Electrical and Electronic Engineering (IJEREEE)

Volume 12, Issue 09, September 2025

VII. CONCLUSION

As the worldwide demand of renewable energy sources is growing rapidly, the efficiency of CSP technology must be improved. Solutions for optimization of CSP plants comprise of high level novel system designs and optimum scheduling of operational parameters. These optimization strategies help Concentrated Solar Power (CSP) plants to maximize energy yield, minimize operating costs and contribute to the stability of the grid, and thereby advance the technology to rank among the cleanest and most sustainable renewable energy sources. In this paper, state of the art CSP plant optimization methodologies are analyzed and applied to the concept of the plant, its practical application and influence over the performance of the system is discussed. In this article, we review and compare optimization methods for sustainable and more efficient solar energy use, namely Concentrated Solar Power (CSP) plant optimization. The findings highlight CSP as a stable, clean energy source that can provide reliable power in high-DNI regions, making a significant contribution to global renewable energy targets.

REFERENCES

[1] Kavuma, C., de Dieu, H. K. J., & Sandoval, D. (2020, October). Reducing Carbon Dioxide Emission Generated by Thermal Power Plants with Solar Power on the Uganda's Electricity Grid. In 2020 International Conference and Utility Exhibition on Energy, Environment and Climate Change (ICUE) (pp. 1-6). IEEE.

[2] Guo, X., Lou, S., Wu, Y., & Wang, Y. (2021). Low-carbon operation of combined heat and power integrated plants based on solar-assisted carbon capture. Journal of Modern Power Systems and Clean Energy, 10(5), 1138-1151.

[3] Beegun, D., Juggurnath, D., Elahee, M. K., &Khoodaruth, A. (2019, November). Design of a concentrated solar power hybrid system for electricity production for a textile manufacturing plant. In 2019 7th International Renewable and Sustainable Energy Conference (IRSEC) (pp. 1-6). IEEE.

[4] Boukelia, T. E., Kabar, Y., &Djimli, S. (2021, October). Development of an ANN model for forecasting time series of cooling performances in CSP plants-Solar tower power plant (Gemasolar) as a case study. In 2020 6th International Symposium on New and Renewable Energy (SIENR) (pp. 1-5). IEEE.

[5] Kumar, K. H., Daabo, A. M., Karmakar, M. K., &Hirani, H. (2022). Solar parabolic dish collector for concentrated solar thermal systems: a review and recommendations. Environmental Science and Pollution Research, 29(22), 32335-32367.

[6] Kumar, M. A., Telagam, N., Chavala, S. M., Sabarimuthu, M., & Prasad, K. (2021, December). Solar Energy System for Indoor Plant Applications using SunFlower Technology. In 2021 IEEE 2nd International Conference on Technology, Engineering, Management for Societal impact using Marketing, Entrepreneurship and Talent (TEMSMET) (pp. 1-6). IEEE.

[7] Abbas, R., Valdés, M., Montes, M. J., &Martínez-Val, J. M. (2017). Design of an innovative linear Fresnel collector by means of optical performance optimization: A comparison with parabolic trough collectors for different latitudes. Solar Energy, 153, 459-470.

[8] Bellos, E., Mathioulakis, E., Papanicolaou, E., &Belessiotis, V. (2018). Experimental investigation of the daily performance of an integrated linear Fresnel reflector system. Solar Energy, 167, 220-230.

[9] Kiwan, S., and Khammash, A. L. (July 23, 2019). "Optical Performance of a Novel Two-Receiver Solar Central Tower System." ASME. *J. Sol. Energy Eng*. February 2020; 142(1): 011005.

[10] Ghazouani, M., Bouya, M., Benaissa, M., Anoune, K., & Ghazi, M. (2020). Thermal energy management optimization of solar thermal energy system based on small parabolic trough collectors for bitumen maintaining on heat process. Solar Energy, 211, 1403-1421.

[11] Nazemi, S. D., & Boroushaki, M. (2016). Design, Analysis and Optimization of a Solar Dish/Stirling System. International Journal of Renewable Energy Development, 5(1).

[12] Nayak, J. K., Kedare, S. B., Banerjee, R., Bandyopadhyay, S., Desai, N. B., Paul, S., &Kapila, A. (2015). A 1 MW national solar thermal research cum demonstration facility at Gwalpahari, Haryana, India. Current Science, 1445-1457.

[13] Kumar A, and Mishra P. India one Solar Thermal Power plant: A case study, Conference: International Congress on Renewable Energy (IOCRE-2013).

[14] Kannaiyan, S., Bokde, N. D., &Geem, Z. W. (2020). Solar collectors modeling and controller design for solar thermal power plant. *IEEE Access*, *8*, 81425-81446.

[15] Olabi, A. G., Onumaegbu, C., Wilberforce, T., Ramadan, M., Abdelkareem, M. A., & Al–Alami, A. H. (2021). Critical review of energy storage systems. *Energy*, *214*, 118987.

[16] Praveen, R. P., Baseer, M. A., &Sankara, N. K. (2018, March). Design. Performance analysis and optimization of a 100 MW concentrated solar power plant with thermal energy storage. In *2018 International Conference on Current Trends towards Converging Technologies (ICCTCT)* (pp. 1-6). IEEE.

[17] Schlecht, M., & Meyer, R. (2021). Site selection and feasibility analysis for concentrating solar power systems. In *Concentrating Solar Power Technology* (pp. 99-125). Woodhead Publishing.

[18] Shen, W., Chen, X., Qiu, J., Hayward, J. A., Sayeef, S., Osman, P., ...& Dong, Z. Y. (2020). A comprehensive review of variable renewable energy levelized cost of electricity. *Renewable and Sustainable Energy Reviews*, *133*, 110301.

[19] Platzer, W. J., & Hildebrandt, C. (2021). Absorber materials for solar thermal receivers in concentrating solar power systems. In *Concentrating Solar Power Technology* (pp. 511-544). Woodhead Publishing.

[20] Coventry, J., &Andraka, C. (2017). Dish systems for CSP. *Solar Energy*, *152*, 140-170.

[21] Srivastva, U., Malhotra, R. K., & Kaushik, S. C. (2015). Recent developments in heat transfer fluids used for solar thermal energy applications. *Journal of Fundamentals of Renewable Energy and Applications*, *5*(6), 1-11.

[22] Kalele, G. (2023, May). Improved Algorithm for Solar Power Systems for Efficient Tracking System. In *2023 3rd International Conference on Advance Computing and Innovative Technologies in Engineering (ICACITE)* (pp. 2595-2598). IEEE.